

# Schedule


Issue date: 28 July 2025  
Valid Until: -



## NO: SAMM 1086

(Issue 2, 28 July 2025 replacement  
of SAMM 1086 dated 03 September 2025)

Page: 1 of 1

<b>LABORATORY LOCATION/ CENTRAL OFFICE:</b>	Testing Laboratory, Ebara Pumps Malaysia Sdn. Bhd. No. 6, Jalan TP3, UEP Subang Jaya Industrial Park, 47620 Subang Jaya, Selangor , 47620, SELANGOR MALAYSIA
	
<b>ACCREDITED SINCE :</b>	28 JULY 2025
<b>FIELD(S) OF TESTING:</b>	MECHANICAL

This laboratory has demonstrated its technical competence to operate in accordance with MS ISO/IEC 17025:2017 (ISO/IEC 17025:2017).

This laboratory's fulfillment of the requirements of ISO/IEC 17025 means the laboratory meets both the technical competence requirements and management system requirements that are necessary for it to consistently deliver technically valid test results and calibrations. The management system requirements in ISO/IEC 17025 are written in language relevant to laboratory operations and operate generally in accordance with the principles of ISO 9001 (see Joint ISO-ILAC-IAF Communiqué dated April 2017).

<b>CENTRAL LOCATION:</b>	Testing Laboratory, Ebara Pumps Malaysia Sdn. Bhd. No. 6, Jalan TP3, UEP Subang Jaya Industrial Park, 47620 Subang Jaya, Selangor , 47620, Selangor
<b>FIELD(S) OF TESTING :</b>	MECHANICAL,

## SCOPE OF TESTING : MECHANICAL

Material / Product Tested	Type Of Test / Properties Measured / Range Of Measurement	Standard Test Methods / Equipment / Techniques
<b>Water Pumps:</b>	Hydraulic performance acceptance test Grade 1, 2 & 3	BS EN ISO 9906: 2012
Fire Pumps & Centrifugal Pumps	Range Flow: Up to 1200 m <sup>3</sup> /hr	ANSI/HI 14.6:2016
	Positive Pressure: Up to 30 bars	MS 2616:2015 (Clause 11.3.2)

Scan this QR Code or visit <https://accreditation.ism.gov.my/public/listing/cab/samm-ct/3005906> for the current scope of accreditation